

BEFORE THE FORUM
FOR REDRESSAL OF CONSUMER GRIEVANCES
IN SOUTHERN POWER DISTRIBUTION COMPANY OF A.P LIMITED TIRUPATI
On this the 21st day of December 2018
C.G.No:143/2017-18/Guntur Circle

Present

Sri. A. Jagadeesh Chandra Rao
Sri. A. Sreenivasulu Reddy
Sri. D. Subba Rao
Sri. Dr. R. Surendra Kumar

Chairperson
Member (Finance)
Member (Technical)
Independent Member

Between

U.Hari Krishna,
Oppicherla,
Karempudi,
Guntur -Dist

Complainant

AND

1.Assistant Engineer/O/Karemchedu
2.Assistant Divisional Engineer/OGurajala
3.Divisional Engineer/OMacherla

Respondents

ORDER

1. Complainant filed a petition before this Forum for redressal of his grievance of low voltage problem to his agricultural service.
2. Respondents No. 1, 2 & 3 submitted their joint written submission stating that the complainant low voltage problem was rectified on 07.07.2018 by erecting 1 No. additional 25KVA distribution transformer and at present there is no interruption to the complainant agriculture service. Respondents have also enclosed the complainant statement addressed to the Chairperson/ CGRF where in the complainant expressed his satisfaction for solving his problem.
3. Complainant when contacted over phone by this Forum 05.12.2018 at 11:10 A.M, expressed satisfaction for resolving his problem.
4. In as much as the grievance of the complainant was resolved by the Respondents, accordingly the case is disposed of in favour of the complainant.

DESPATCHED

DATE 21/12

C.G.No.143/2017-18/Guntur Circle

