

BEFORE THE FORUM
FOR REDRESSAL OF CONSUMER GRIEVANCES
IN SOUTHERN POWER DISTRIBUTION COMPANY OF A.P LIMITED TIRUPATI
On this the 28th day of May 2019
C.G.No:18/2018-19/Guntur Circle

Present

Sri. A. Jagadeesh Chandra Rao
Sri. A. Sreenivasulu Reddy
Sri. D. Subba Rao
Sri. Dr. R. Surendra Kumar

Chairperson
Member (Finance)
Member (Technical)
Independent Member

Between

U.Venkateswara Rao & Others,
Thummala,
Repalle,
Guntur –Dist.

Complainant

AND

1. Assistant Engineer/O/Repalli
2. Assistant Divisional Engineer/O/Repalli
3. Divisional Engineer/O/Tenali

Respondents

ORDER

1. Complainant and several others presented a complaint before this Forum wherein they have informed that they are cultivating aqua culture. 33/11 KV sub-station is very nearer to their fields and hence requested to provide 24 Hrs power supply through big transformer so that they can cultivate aqua culture without any difficulty. They are not in a position to pay the power bills for the single phase connections. Lines are passing over their tanks from Nirmala Nagar sub-station, the same may be converted into 24 Hrs supply. Conversion of supply from 7 Hrs to 24 Hrs has already been effected from Porumeraka to Palakurthy line and also Rajukalava. In the similar lines supply may be extended to their fields. Further they have also submitted that they are not in a position to bear the cost of the new line.
2. Respondent No.2 in his written submission has explained that respondent No.1 had inspected all the services personally and noticed that two No's AGL services are existing in Thummala and 1 No AGL service in Bondalagaruvu and 1 No. AGL service at Nirmal Nagar Distribution are existing and supply is being fed from 11 KV Nirmal Nagar feeder for 7 Hrs three phase supply which is emanating from 33/11 KV SS Potumeraka due to which it is not possible to convert the

DESPATCHED

DATE 26/6

C.G.No.18/2018-19_Guntur Circle

