

**BEFORE THE FORUM**  
**FOR REDRESSAL OF CONSUMER GRIEVANCES**  
**IN SOUTHERN POWER DISTRIBUTION COMPANY OF A.P LIMITED TIRUPATI**

**On this the 18<sup>th</sup> day of December 2018**

**C.G.No:13/2018-19/kadapa Circle**

**Present**

**Sri. A. Jagadeesh Chandra Rao**  
**Sri. A. Sreenivasulu Reddy**  
**Sri. D. Subba Rao**  
**Sri. Dr. R. Surendra Kumar**

**Chairperson**  
**Member (Finance)**  
**Member (Technical)**  
**Independent Member**

**Between**

M/s Indus Towers Ltd,  
Survey No.133,4-51,  
8th floor,  
SLN Terminus,  
Besides Botanical Gardens, Gachibowli ,  
Hyderabad

**Complainant**

**AND**

1.AAO/Porumamilla  
2.AE/Kalasapadu  
3.ADE/Pourmamilla  
4.DE/Mydukur

**Respondents**

\*\*\*\*\*

**ORDER**

1. Complainant Sri V.Madan Mohan Reddy had represented on behalf of Indus towers Pvt, Ltd, Hyderabad and he had filed a petition in this Forum regarding Revision of CC bill for the Cat-2. Sc.No:2633212000085 from September 2016 to December 2017.
2. Respondent No.2 had submitted written submission to the Forum. In his submission he had stated that during the months of 10/2017, 11/2017 and 12/2017 the CC Charges were very high due to delink in the R-Phase. Now on 21.05.2017 a series meter was fixed with R-Phase delink to the original meter in that premises. After observing the consumption in both the meters it was found that the difference in consumption is very high in series meter. So revision of bill proposals were send to S-ERO, Porumamilla with average consumption. After revision an amount of Rs.5 Lakhs/- was withdrawn.
3. Complainant had also submitted his satisfaction letter towards revision of the CC bill.

**DESPATCHED**

**DATE** 21/12

C.G.No:13/2018-19/Kadapa Circle

