

BEFORE THE FORUM
FOR REDRESSAL OF CONSUMER GRIEVANCES
IN SOUTHERN POWER DISTRIBUTION COMPANY OF A.P LIMITED TIRUPATI

On this the 30th day of January 2020

C.G. No: 27/2019-20/Kurnool Circle

Present

Sri. Dr. A. Jagadeesh Chandra Rao
Sri. A. Ramdas
Sri. Dr. R. Surendra Kumar

Chairperson
Member (Finance)
Independent Member

Between

T.Mukunda Rao,
S/o. T. Gopal Rao,
1/3631,
Munepa Nagar,
Yemmiganur,
Kurnool -Dist .

Complainant

AND

1. Assisatn Executive Engineer/O/Yemmiganur
2. Deputy Executive Engineer/O/Yemmiganur
3. Executive Engineer/O/Adoni

Respondents

ORDER

1. Complainant presented a petition before the Forum regarding rectification of loose service wires hanging before this house.
2. Respondent No. 3 submitted that service wires of LT service bearing No's 24383, 32538, 24384 and 24940 were passing in front of the petitioner house and the said service connection wires are hanging due to no support of GI Wire. The same were taped with GI wires and service connection wires are now tightened as well as adjusted to proper height of the building.
3. A personal hearing through video conferencing was conducted on 16.10.2019. Only respondents were present. In the hearing respondents reiterated the same version. So, respondents are directed to submit the photo copies of work executed for redressing the grievance of the complainant. Accordingly the respondents had enclosed the photo copies.

DESPATCHED
DATE 03/02

