

**CONSUMER GRIEVANCES REDRESSAL FORUM**

**SOUTHERN POWER DISTRIBUTION COMPANY OF A.P LIMITED.**

**TIRUPATI**

**This 21<sup>st</sup> day of December' 2024**

**C.G.No.134/2024-25/Kadapa Circle**

**CHAIRPERSON** Sri. V. Srinivasa Anjaneya Murthy  
Former Principal District Judge

**Members Present**

Sri. K. Ramamohan Rao Member (Finance)  
Sri. S.L. Anjani Kumar Member (Technical)

***Between***

Sri. Y. Chandra Mohan, Kothacheruvu (V),  
Badvel (M), Kadapa District. Complainant


***AND***

1. Dy. Executive Engineer/O/Badvel
2. Executive Engineer/O/Mydukur Respondents

This complaint came up for final hearing before this Forum through video conferencing on 19.12.2024 in the presence of the respondents, complainant remained absent and having considered the material placed by both the parties, this Forum passed the following.

**ORDER**

01. The complainant filed the complaint during the Vidyut Adalat conducted on 04.09.2024 at Badvel stating that the electric wires in the 11 KV line passing through his fields are hanging endangering human lives and they are to be tightened.



02. The said complaint was registered as C.G.No.134/2024-25 and notices were issued to the respondents calling for their response. The respondents submitted their response stating that on receiving the complaint, they erected one middle pole in the line and tightened loose wires.
03. Heard respondents through video conferencing. Complainant. remained absent. The respondents submit that on receiving the complaint, they erected one middle pole in the line and tightened loose wires. The complainant when we contacted him through phone admitted the same and requested to close the complaint. Since the grievance of the complainant is redressed, the complaint is closed. There is no order as to costs.
04. The complainant is informed that if he is aggrieved by the order of the Forum, he may approach the Vidyut Ombudsman, 3<sup>rd</sup> Floor, Plot. No.38, Adjacent to Kesineni Admin Office, Sriramachandra Nagar, Mahanadu Road, Vijayawada-08 in terms of Clause.13 of Regulation.No.3 of 2016 of Hon'ble APERC within 30 days from the date of receipt of this order and the prescribed format is available in the website vidyutombudsman.ap.gov.in.

Typed to dictation by the computer operator-2 corrected and pronounced in the open Forum on this 21<sup>st</sup> day of December'2024.

  
CHAIRPERSON

  
Member (Finance)

  
Member (Technical)

**Documents marked**

For the complainant: Nil

For the respondents: Nil

**Copy to the**

Complainant and All the Respondents

**Copy Submitted to**

The Chairman & Managing Director/Corporate Office/APSPDCL/  
Tirupati.

The Vidyut Ombudsman, 3<sup>rd</sup> Floor, Plot No.38, Sriramachandra  
Nagar, Vijayawada-08.

The Secretary/Hon'ble APERC/Vidyut Niyantrana Bhavan, Adjacent  
to 220/132/33/11 KV AP Carbides Sub Station, Dinnedevaram  
Road, Kurnool-518002, State of Andhra Pradesh.

The Stock file.

*Copy*  
*21/12/24*